

4-8-03

MO.NO.....	Description.....	Part No	Part Noun Qual.....	Part Qty Issued	Tot Material Act	Act Tot Labor Cost	Actual Tot Cost
02-60456-00	Capital Tracking Work Order for addition of primary superheater tubing in both units.	D	BASE OPTION: ENGINEERING DESIGN AND MATERIALS TO RELOCATE THE DRUM-LEVEL SENSING LINES ACCORDING TO B&W'S PROPOSED SCOPE OF SUPPLY (ENGINEERING AND MATERIALS ONLY) DATED AUGUST 8, 2002	0	1,539,961.69	50,731.79	1,590,693.48
		D	OPTION 1: ENGINEERING DESIGN AND MATERIALS TO MODIFY CYCLONE DIRECTIONAL SPOUTS ACCORDING TO B&W'S PROPOSED SCOPE OF SUPPLY DATED AUGUST 8, 2002	0			
		D	OPTION 2: ENGINEERING DESIGN AND MATERIALS TO MODIFY STEAM DRUM INTERNAL BAFFLES ACCORDING TO B&W'S PROPOSED SCOPE OF SUPPLY DATED AUGUST 8, 2002	0			
		D	SERVICE: PRELIMINARY ENGINEERING ASSOCIATED WITH BOILER MODIFICATIONS. WORK WILL INCLUDE ENGINEERING REVIEW OF EXISTING IGS SYSTEM EQUIPMENT, BOILER MODEL DEVELOPMENT, AND PRELIMINARY DESIGN OF BOILER MODIFICATIONS.	0			
		D	DESIGN, SUPPLY, AND INSTALL: BOILER UPRATE MODIFICATIONS ON UNIT 1 AND UNIT 2	0			
		D	SERVICE, CARBON MONOXIDE MODELING	0			

IP7_035611

Costs for WO #02-60456-0 AND ALL ASSOCIATED SUBS

MO.NO.....	Description.....	Part No	Part Noun Qual.....	Part Qty Issued	Tot Material Act	Act Tot Labor Cost	Actual Tot Cost
			SEE ATTACHED STANDARD AGREEMENT				
		D	SERVICE: CONSTRUCT AND EXECUTE BOILER COMPUTER MODEL TO ACCURATELY REFLECT MODIFICATIONS SPECIFIED BY BOILER CONTRACTOR AND IPSC IN ACCORDANCE WITH PREVIOUSLY SENT BOILER MODEL SPECIFICATIONS 45586 AND TERMS & CONDITIONS.	0			
			MODELING WORK SHALL BE COMPLETED AND RECOMMENDATIONS PROVIDED TO IPSC WITHIN SIXTY (60) DAYS OF MODELING CONTRACT AWARD.				
			MODELING RECOMMENDATIONS SHALL INCLUDE SPECIFIC DIRECTION REGARDING ADEQUACY OF DESIGN IN OVERFIRE AIR MIXING/PENETRATION; IMPACT OF PLATEN SURFACE ON STEAM TEMPERATURES, AND CONFIRMATION OF LOI AND FURNACE CLEANLINESS TARGETS.				
		D	SERVICES: ENGINEERING, STRUCTURAL EVALUATION OF 9TH FLOOR DIAGONAL BRACE INTERFERENCE WITH NEW OVERFIRE AIR DUCT. TO INCLUDE ON-SITE INSPECTION AND ANALYSIS FOR RELOCATION/SUBSTITUTION OF 4 EXISTING BRACES.	0			
		D	SERVICE: ENGINEERING, STRUCTURAL EVALUATION OF 9TH FLOOR DIAGONAL BRACE	0			

IP7_035612

Costs for WO #02-60456-0 AND ALL ASSOCIATED SUBS

MO.NO.....	Description.....	Part No	Part Noun Qual.....	Part Qty Issued	Tot Material Act	Act Tot Labor Cost	Actual Tot Cost
------------	------------------	---------	---------------------	-----------------	------------------	--------------------	-----------------

INTERFERENCE WITH NEW OVERFIRE
AIR DUCT; EVALUATION TO
INCLUDE ON-SITE INSPECTION &
ANALYSIS FOR
RELOCATION/SUBSTITUTION OF
FOUR (4) EXISTING BRACES

**NOTE: WORK IS COVERED UNDER
TERMS & CONDITIONS
OF CONTRACT 03-45583 &
INCORPORATED BY
REFERENCE HEREIN**

D	SERVICES: ENGINEERING, STRUCTURAL ALTERATIONS ASSOCIATED WITH OVERFIRE AIR DUCT DESIGN SIMPLIFICATION; TO INCLUDE: DESIGN OF STRUCTURAL ALTERATIONS OF DUCT ROUTING AT THE NINTH LEVEL OF UNIT 1 & 2 BOILERS.			0			
---	--	--	--	---	--	--	--

**NOTE: DETAILED DESIGN OF
SOUTH CORNER
SECTIONS AT THE NINTH
LEVEL IS
CONTINGENT ON APPROVAL
OF REFINED
CONCEPTUAL ESTIMATE IN
THAT LOCATION**

**NOTE: DRAWINGS SUFFICIENT
FOR PROCUREMENT AND
FABRICATION WORK WILL
BE PROVIDED AS PART
OF THIS WORK**

D	BOARD, ANALOG TO DIGITAL CONVERTER, 4-20MA OUTPUT, ISOLATED, 2 CHANNEL, WITH QUARTER TURN CONNECTOR,			0			
---	---	--	--	---	--	--	--

IP7_035613

Costs for WO #02-60456-0 AND ALL ASSOCIATED SUBS

MO.NO.....	Description.....	Part No	Part Noun Qual.....	Part Qty Issued	Tot Material Act	Act Tot Labor Cost	Actual Tot Cost
			FOXBORO P/N 3A2-D21B				
		D	BOARD, ANALOG TO DIGITAL CONVERTER, 4-20MA INPUT, 4 CHANNEL, WITH QUARTER TURN CONNECTOR, FOXBORO P/N 3A4-I2DA	0			
		D	ON SITE SERVICE: CODE COMPLIANCE, HARTFORD STEAM BOILER REPRESENTATIVE TO COORDINATE/APPROVE MODIFICATIONS PLAN FOR NEW OFA SYSTEM WITH TEI	0			
		D	RENTAL: BOILER TEST EQUIPMENT FOR THREE (3) MONTHS, GAS ANALYZERS, PRECISION ACCURACY, NOX-NO-NO2 (3), CO (3), CO2 (2), O2 (3), DATA LOGGER AND CONTROLLER DATA ACQUISITION SYSTEM	0			
			NOTE: SUPPLY TEST TECHNICIAN FOR INITIAL SETUP AND TRAINING				
		51287	FITTING, SS CONNECTOR	25			
		51273	FITTING, BRASS CONNECTOR	35			
		5284	TAPE, TEFLON	6			
		54183	VALVE, 00.25 BALL	1			
		D	VALVE, BALL, TUBE-TO-TUBE, 1/4" X 1/4", 3-WAY, WHITEY P/N B43XS4	0			
		D	CONNECTOR, PORT, 1/4", BRASS, SWAGELOK P/N B-401-PC	0			
		D	CABLE, INSTRUMENT, FLAME RETARDANT, SHIELDED-TWISTED, 600 V, #16 AWG, 4-PAIR, FR-XLPE/HYP OR FR-EPR/HYP, 90 DEG C MAX OPERATING TEMPERATURE, INDIVIDUAL PAIR,	0			

IP7_035614

Costs for WO #02-60456-0 AND ALL ASSOCIATED SUBS

MO.NO.....	Description.....	Part No	Part Noun Qual.....	Part Qty Issued	Tot Material Act	Act Tot Labor Cost	Actual Tot Cost
	OVERALL SHIELDED, PLANT STANDARD, ANIXTER CATALOG NO. 2RH-1604SPOS						
	D CABLE, INSTRUMENT, FLAME RETARDANT, SHIELDED-TWISTED, 600 V, #16 AWG, 1-PAIR, FR-XLPE/HYP OR FR-EPR/HYP, 90 DEG C MAX OPERATING TEMPERATURE, INDIVIDUAL PAIR, OVERALL SHIELDED, PLANT STANDARD, ANIXTER CATALOG NO. 2RH-1601POS			0			
	D CABLE, INSULATED, 600 V, FLAME RETARDANT, #12 AWG, 3-CONDUCTOR, XLPE/HYP, 90 DEG C MAX OPERATING TEMPERATURE, PLANT STANDARD, ANIXTER CATALOG NO. 2RH-1203			0			
	50120 BATTERY, 001.5 VOLT			32			
	50118 BATTERY, 001.5 VOLT			28			
	5064 FLASHLIGHT, 2 CELL			11			
	53199 COVERALL, DISPOSABLE			2			
	D SYSTEM OVERFIRE AIR, FOR UNIT 1			0			
	D INVOICE NO. 6268-1 BOILER MODEL & GENERAL ARRANGEMENT DRAWINGS MANUFACTURING DRAWINGS RAW MATERIAL ORDERED & DELIVERED			0			
	D CABLE, NEC RATED TC, INSTRUMENT, 4-PAIR CONDUCTOR, 16 AWG, 600 VOLT, 90 DEG C, XLPE INSULATION & HYPALON			0			

IP7_035615

Costs for WO #02-60456-0 AND ALL ASSOCIATED SUBS

MO.NO.....	Description.....	Part No	Part Noun Qual.....	Part Qty Issued	Tot Material Act	Act Tot Labor Cost	Actual Tot Cost
	JACKET, SHIELDED, WITH DRAIN WIRE, 3-PAIR BLACK AND WHITE, WITH NUMBERS, ANIXTER CAT NO. 2RH-1604SPOS						
48286	BUCKET, UTILITY			11			
74894	LID, 5-GAL BUCKET			10			
D	CABLE, INSTRUMENT, 600 V, 16 AWG, SINGLE TRIAD, FIRE RESISTANT, XLPE, HYPALON, 90 DEG C MAX OPERATING TEMPERATURE, ANIXTER CAT NO. 2RH1601TOS			0			
D	CABLE, POWER, 12 AWG, 4-CONDUCTOR, COATED COPPER, FIRE RETARDANT, XLPE, HYPALON, 90 DEG C MAX OPERATING TEMPERATURE, ANIXTER CAT NO. 2RH1204			0			
37779	GAS, CALIBRATION			1			
50126	PAINT, SPRAY			6			
50062	TAPE, DUCT			2			
1996	BATTERY, 001.5 VOLT			6			
D	INVOICE NO. 138799 IPSC REVISED STEEL FOR OFA			0			
35082	LAMP, SODIUM			1			
3267	FITTING, COPPER SOLDER			50			
5614	TAPE, ELECTRICAL			2			
50121	MARKER, METAL			1			
53637	STONE, SOAP			2			
D	MODIFY UNIT 1 STEAM DRUM LEVEL TAPS ON INSIDE IN ACCORDANCE WITH B&W DESIGN DRAWINGS			0			
D	BOARD, ANALOG-TO-DIGITAL CONVERTER, 4-20 MA OUTPUT, ISOLATED, 2-CHANNEL, INCLUDES QUARTER TURN CONNECTOR, FOXBORO P/N 3A2-D21B			0			

IP7_035616

Costs for WO #02-60456-0 AND ALL ASSOCIATED SUBS

WO.NO.....	Description.....	Part No	Part Noun Qual.....	Part Qty Issued	Tot Material Act	Act Tot Labor Cost	Actual Tot Cost
		2627	BOARD, FOXBORO (CCS)	0			
		D	CABLE, INSULATED, 600 V, FLAME RETARDANT, #12 AWG, 3-CONDUCTOR, XLPE/HYP, 90 DEG C MAX OPERATING TEMPERATURE	0			
		D	Stainless steel rod, grade 347 H.	0			
		D	FABRICATE AND DELIVER: DUCT WORK, TO INCLUDE THE FOLLOWING: 36"/72" TURNING VANE SET, 30"/68" RECTANGULAR DUCT SECTION, 30"/68" RECTANGULAR 90 DEG ELBOW, 68"/30" SQUARE-TO-ROUND TRANSITION, 46" ROUND 90 DEG ELBOW, 12" THROAT, AND END CAP, FLAT SHEET SIZED TO EXISTING DUCT **PER SKETCHES PERVIOUSLY SENT BY BRET KENT**	0			
		36584	WELD MATERIAL, ELECTRODE	10			
		D	TAPE MEASURE, 30' X 3/4", AUTO RETRACT, STANLEY P/N 33-430	0			
		56150	OIL, CUTTING	1			
		D	CABLE, POWER, INSULATED, 600 VOLT, FLAME RETARDANT, 4-CONDUCTOR, 12 AWG, XLPE/HYPLON, 90 DEG C MAX OPERATING TEMPERATURE	0			
		D	CABLE, INSTRUMENT, SHIELDED-TWISTED, FLAME RETARDANT, 600 VOLT, 16 AWG,	0			

PO # 03-31450

HVAC

\$6187.00
408 35

HVAC

IP7_035617

Costs for WO #02-60456-0 AND ALL ASSOCIATED SUBS

MO.NO.....	Description.....	Part No	Part Noun Qual.....	Part Qty Issued	Tot Material Act	Act Tot Labor Cost	Actual Tot Cost
			INDIVIDUAL PAIR, OVERALL SHIELDED, 1-TRIAD FR-XLPE/HYPLON OR FR-EPR/HYPLON, 90 DEG C MAX OPERATING TEMPERATURE				
		48361	LAMP, SODIUM	2			
		50208	BOX, JUNCTION	3			
		19933	BOX, JUNCTION	3			
		7738	CAP, 01.50 THREADED	3			
		51607	FITTING, BULKHEAD UNION	21			
		45744	LEAD, THERMOCOUPLE	1			
		71736	GLASSES, SAFETY	2			
		50985	U-BOLT, 0.25-20 ALLOY	13			
		50986	U-BOLT, 0.25-20 ALLOY	3			
		50815	WASHER, LOCK	32			
		72786	SUIT, BAGHOUSE	1			
		75693	SHIELD, TUBE	4			
		D	GAS, CALIBRATION, PRIMARY STANDARD, CO 10,000 PPM, BALANCE N2 **A \$50 EXPEDITING FEE, AND A \$10 PER MONTH CYLINDER RENTAL FEE WILL BE ADDED TO THE INVOICE**	0			
		5177	GLASSES, SAFETY	0			
		50122	MARKER, METAL	0			
		53358	CRAYON, TEMILSTICK	1			
		53355	CRAYON, TEMILSTICK	2			
		50108	ANTI-SEIZE, LO TEMP	1			
		52441	BRUSH, ACID	2			
		41712	DETECTOR, LEAK	2			
02-60456-01	INSTALL TEMPORARY POWER ON THE 9TH AND 14TH FLOORS OF THE BOILER FOR BOILER OVER-FIRE AIR MODS.	46943	<u>CORD, PORTABLE</u>	4000	18,350.58	3,699.73	22,050.31
		D	SAFETY SWITCH, 100 AMP, HEAVY-DUTY, 600 V, SINGLE THROW, NON-FUSIBLE, 3-WIRE, SQUARE D P/N HU363 OR EQUAL	0			

IP7_035618

Costs for WO #02-60456-0 AND ALL ASSOCIATED SUBS

MO.NO.....	Description.....	Part No	Part Noun Qual.....	Part Qty Issued	Tot Material Act	Act Tot Labor Cost	Actual Tot Cost
		65608	BREAKER, 00100.0 AMP	8			
		53478	STEEL, ANGLE	23			
		23298	STEEL, CHANNEL	0			
		53497	STEEL, CHANNEL	40			
		76126	CONNECTOR, CORD	10			
		30300	PAINT, SPRAY	2			
		57589	WIRE (ELECT), THHN	63			
		5457	TERMINAL, 1 HOLE LUG	10			
		5647	TERMINAL RING TONGUE	40			
		51753	TY-RAP, CABLE	149			
		50179	TY-RAP, CABLE	470			
		43272	SHEET, LAMINATING	0			
		52480	BREAKER, 00050.0 AMP	1			
		D	BREAKER, 100 AMP, 2-POLE, 480 V, WESTINGHOUSE, EHD P/N 2100	0			
		D	200 AMP WESTINHOUSE BREAKER, POWER PANEL, EHB 2100, 2 POLE FOR A 208V PANEL.	0			
		62193	CONNECTOR, CORD CAP	4			
		59871	BREAKER, 00080.0 AMP	1			
		D	FLOWMETER, GAS, 10" SCALE, RANGE SCFH 10-100, 1/2" NPT, DWYER INSTRUMENTS RM RATE-MASTER, M/N RMC-102-SSV	0			
		D	FLOWMETER, GAS, 10" SCALE, RANGE SCFH 40-400, 1/2" NPT, DWYER INSTRUMENTS RM RATE-MASTER, M/N RMC-104-SSV	0			
02-60456-02	TIME EXPENDED FOR GARY SPERRY TO REMOVE SOOTBLOWER CAB INTERFERENCES FOR NEW SUPERHEATER UPRATE PROJ.			0	0.00	1,595.97	1,595.97
02-60456-03	TIME EXPENDED ON 1/7/03 FOR TWO ELECTRIC SHOP APPRENTICES TO HELP GARY SPERRY.			0	0.00	918.00	918.00
02-60456-04	REMOVE INTERFERING GUTTER FOR NEW OVER FIRE AIR DUCTWORK AND REWORK IN CONDUIT.	50609	ROD, ALLTHREAD	34	167.63	5,384.31	5,551.94
		50618	ROD, ALLTHREAD	0			
		58400	CONDUIT, RIGID	0			

IP7_035619

Costs for WO #02-60456-0 AND ALL ASSOCIATED SUBS

MO.NO.....	Description.....	Part No	Part Noun Qual.....	Part Qty Issued	Tot Material Act	Act Tot Labor Cost	Actual Tot Cost
		18284	UNISTRUT, CHANNEL	0			
		58406	CONDUIT, EMT	0			
02-60456-05	ASSIST WITH WIRING ON BOILER OVER-FIRE AIR PROJECT DURING U1 OUTAGE. WILL REQUIRE PRE-OUTAGE WORK.	49685	VALVE, 00.50 BALL	700	7,456.68	10,659.48	18,116.16
		57677	PIPE, COPPER	0			
		34954	FITTING, COPPER SOLDER	0			
		3267	FITTING, COPPER SOLDER	0			
		65672	FITTING, COPPER SOLDER	0			
		D	REDUCER, COUPLING, SWEAT, 1-1/8" X 7/8" OD, 1" X 3/4" NOMINAL, COPPER, JOHNSTONE P/N R53-679.	0			
		23955	TUBING, 00.500 OD	0			
		51219	FITTING, SS TEE	0			
		51211	FITTING, SS ELBOW	0			
		D	FITTING, 1/2" BULKHEAD, 1/2" TUBE X 1/2" TUBE, SWAGelok P/N SS-810-61, SSP P/N ISS-D8BU	0			
		51294	FITTING, SS CONNECTOR	0			
		6612	ANTI-SEIZE, HI TEMP	0			
		D	HOSE, FLEXIBLE, SS, WITH 304 SS BRAID ON OUTSIDE, 316 SS CORE TUBE, AND 1/2" TUBE CONNECTOR ON BOTH ENDS, 1,500 DEG F WORKING TEMPERATURE, > 250 PSI PRESSURE RATING, SSP P/N 8CF1632FN32FNS6-23"	0			
		D	DESLAGGER, AUTOMATIC PORT, SYN-FAB P/N MSS0034	0			
		D	WALLBOX, HD, SYN-FAB P/N SAM0007	0			
		49988	PLATE, CHECKER	0			
		7739	CAP, 02.00 THREADED	0			
		25443	PIPE, SEAMLESS	0			
		57539	THERMOCOUPLE, TYPE E	0			
		57175	FITTING, BRASS CONNECTOR	0			
		77301	TUBING, 00.500 OD	0			
		2627	BOARD, FOXBORO (CCS)	0			
02-60456-06	SEND OUT FOR REBUILD, BREAKER, 80 AMPS, 3 POLES,	D	REPAIR AND RETURN, BREAKER,	0	0.00	0.00	0.00

IP7_035620

Costs for WO #02-60456-0 AND ALL ASSOCIATED SUBS

MO.NO.....	Description.....	Part No	Part Noun Qual.....	Part Qty Issued	Tot Material Act	Act Tot Labor Cost	Actual Tot Cost
	600 VOLT MOLDED CASE, WESTINGHOUSE #HFB3080.		CIRCUIT, MOLDED CASE, 80 AMPS, 3 POLE, 600 VOLT, WESTINGHOUSE #HFB3080. REBUILD TO LIKE NEW CONDITION, TEST AND RETURN.				
02-60456-07	INSTALL SCAFFOLDING AS PER DARWIN BILLS NEEDS AND INSTRUCTIONS, CONTACT DARWIN			0	0.00	299.50	299.50
02-60456-08	UNIT 1 PREOUTAGE: DISCONNECT AND REMOVE ELECTRICAL FROM N/S 9TH FL WALL BLOWERS.			0	0.00	618.97	618.97
02-60456-09	REPBUILD AND/OR REPAIR 0050.0 AMP BREAKER.			0	0.00	0.00	0.00
02-60456-10	UNIT 1 "OVER-FIRE CONTRACTOR COST TRACKER" (FOR PHIL HAILES)	76469	ICE, CUBED	430	4,263.84	459.36	4,723.20
		5057	SEAL, OIL	0			
		5707	RAGS, COTTON	50			
		41973	CAN, SAFETY	2			
		50744	CLAMP, WIRE ROPE	8			
		36655	PLANK, SCAFFOLDING	20			
		50742	CLAMP, WIRE ROPE	12			
		23467	VALVE, 01.00 GLOBE	0			
		45826	VALVE, 01.00 GLOBE	1			
		23316	STEEL, ANGLE	20			
		15123	ELBOW, 02.00 SOCKETWELD	2			
		7494	CAP, 02.00 SOCKETWELD	1			
		45078	REDUCER, 02.00 THREADED	1			
		72785	SUIT, BAGHOUSE	1			
		53523	STOCK, SHIM	1			
		12613	TEE, 00.75 THREADED	3			
		12803	TEE, 00.75 THREADED	2			
		52104	METAL SCREW, 0.25 SELF-DRILL	1000			
		52105	METAL SCREW, 0.25 SELF-TAP	1000			
		52106	METAL SCREW, 0.25 SELF-TAP	1000			
		52107	METAL SCREW, 0.25 SELF-TAP	1000			
		77300	SCREW, METAL SELF-TAPPING	2000			
		60945	STAPLE, WIDE CROWN	0			
		22466	TUBING, 02.50 OD	0			
		18345	U-BOLT, CONDUIT/PIPE	8			
		7442	STEEL, ANGLE	100			
		51342	CAP SCREW, 0.250-20	10			
		50691	BOLT, 0.625-11 SS	92			

Warehouse charges to TBI

IP7_035621

Costs for WO #02-60456-0 AND ALL ASSOCIATED SUBS

MO.NO.....	Description.....	Part No	Part Noun Qual.....	Part Qty Issued	Tot Material Act	Act Tot Labor Cost	Actual Tot Cost
		53346	CRAYON, TEMILSTICK	5			
		53345	CRAYON, TEMILSTICK	3			
		16041	NIPPLE, 00.75 THREADED	1			
		57341	LAMP, METAL HALIDE	2			
		71474	REFRACTORY, RAMABLE	0			
		38189	NUT, 000.625	20			
		50716	NUT, 000.625	0			
		50617	ROD, ALLTHREAD	4			
		55730	WELD MATERIAL, CODE ELECTRODES	50			
		1998	EYEGLOSS, CLEANER	0			
		31161	STATION, CLEANING	2			
		53407	STEEL, ROUND	30			
		61057	ELBOW, 01.00 SOCKETWELD	2			
		15132	ELBOW, 01.00 SOCKETWELD	1			
		56171	PIPE, SEAMLESS	4			
		50099	TAPE, ELECTRICAL	1			
		50821	WASHER, FLAT	274			
		52050	WASHER, FLAT	200			
		23350	STEEL, ROUND	72			
		50118	BATTERY, 001.5 VOLT	6			
		50115	BATTERY, 001.5 VOLT	6			
		50126	PAINT, SPRAY	3			
		10989	ELBOW, 02.00 SOCKETWELD	8			
		55731	WELD MATERIAL, CODE ELECTRODES	50			
		5273	WELD MATERIAL, ELECTRODE	50			
		13934	ELBOW, 02.50 BUTTWELD	1			
		50902	PIN, COTTER	2			
		53655	WELD MATERIAL, ELECTRODE	100			
		41416	COMPOUND, SEALANT	6			
		15199	ELBOW, 01.00 SOCKETWELD	5			
		10985	ELBOW, 01.00 SOCKETWELD	10			
		7935	COUPLING, 01.00 SOCKETWELD	6			
		48404	U-BOLT,	12			
		18342	U-BOLT, CONDUIT/PIPE	12			
		50077	COMPOUND, SEALANT	4			
		51000	BLANKET, FIRE	42			
		54713	STEEL, TUBING	134			
		53488	STEEL, FLATBAR	0			
		66251	STEEL, CHANNEL	0			

IP7_035622

Costs for WO #02-60456-0 AND ALL ASSOCIATED SUBS

MO.NO.....	Description.....	Part No	Part Noun Qual.....	Part Qty Issued	Tot Material Act	Act Tot Labor Cost	Actual Tot Cost
02-60456-11	PROVIDE I&C SUPPORT IN OVER FIRE AIR PROJECT. TUBING, WIRING, INSTALLATION AND TESTING WILL BE REQUIRED FOR CAMS AIR MONITOR SYSTEMS.			0	0.00	0.00	0.00
02-60456-12	UNIT 1 "OVER-FIRE CONTRACTOR COST TRACKER" (FOR BRET KENT) FOR SAFEWAY SCAFFOLD	3320	PROPANE, GAS	98	181.36	0.00	181.36
		76469	ICE, CUBED	35			
		5282	TAPE, ELECTRICAL	2			
		50062	TAPE, DUCT	1			
		32724	FUEL, UNLEADED GAS	12			
02-60456-13	PROVIDE ELECTRICAL SUPPORT OF THE OVER FIRE AIR PRODJECT. REMOVE LIGHTS ETC.	51720	TOWEL, CELLULOSE	14	22.84	2,119.49	2,142.33
		18284	UNISTRUT, CHANNEL	0			
		19911	UNISTRUT, CHANNEL	0			
		58406	CONDUIT, EMT	0			
02-60456-14	TIME EXPENDED FOR OPERATORS ASSISTING PHIL HAILES DURING THE UNIT OUTAGE.			0	0.00	9,729.15	9,729.15
02-60456-15	RETURN PRINTED OUTPUT BOARD TO FOXBORO FOR REPAIR/REPLACEMENT.	D	REPAIR/REPLACE AND RETURN: BOARD, PRINTED OUTPUT FOXBORO P/N 3A2-D2I IPSC STOCK #2627	0	0.00	0.00	0.00
02-60456-16	UNIT 1 "OVER-FIRE COST TRACKER" FOR BOILER PERFORMANCE TESTING, (AARON NISSON)	D	UNIT 1 BOILER PERFORMANCE TESTING FOR PRE AND POST OUTAGE MODIFICATIONS (OVERFIRE AIR ND PLATEN EXTENSION) **TEST EQUIPMENT RENTAL FROM PGT BILLED ON A MONTHLY BASIS**	5	51,220.40	0.00	51,220.40
		D	BOILER PERF TEST EQUIPMENT RENTAL 1ST MONTH EQUIPMENT RENTAL FOR 3 SETS- O2, CO, CO2 & NOX, PLUS DATA ACQUISITION SYSTEM	0			
		D	TUBING, IMPERIAL, POLYFLO, THERMOPLASTIC POLYETHYLENE, NATURAL, 3/8" OD, 66-D, 100 FT/RL	0			
		61520	VALVE, BALL	0			

IP7_035623

Costs for WO #02-60456-0 AND ALL ASSOCIATED SUBS

MO.NO.....	Description.....	Part No	Part Noun Qual.....	Part Qty Issued	Tot Material Act	Act Tot Labor Cost	Actual Tot Cost
	D DESICCANT, T.H.E., 100% INDICATING, 6-8 MESH, EM SCIENCE P/N EM-DX0017-1, 4/CS			0			
	D REGULATOR, 2-STAGE, FOR 350 CGA TANK CONNECTION, BRASS, US WELDING P/N APE-330-350, 3-30# DELIVERY			0			
	D SECOND MONTH BOILER TEST EQUIPMENT RENTAL FOR UNIT 1 PRE-OUTAGE BASELINE (STATE UDAQ REQUESTED), ALSO INCLUDES MANPOWER SUPPORT			0			
	D Rental of CO gas analyzers (2) for boiler acceptance testing (plus test required testing) We have overranged original analyzers which were set for 1000 ppm, replacements will be 10,000ppm (or 1.0%) Reference quote from PGT P03-1076.			0			
	D RENTAL: TWO (2) GAS ANALYZER, 10,000 PPM OR 1.0%, FOR BOILER ACCEPTANCE TESTING, PLUS TEST REQUIRED TESTING **REFERENCE QUOTE FROM PGT NO. P03-1076**			0			
02-60456-17	UNIT 1 "OVER-FIRE CONTRACTOR COST TRACKER" (FOR KEN NIELSON) FOR CONTROLS INSTALLATION	50810	NUT, 000.3125	184	572.85	0.00	572.85
	50816 WASHER, LOCK			0			
	50823 WASHER, FLAT			0			
	50986 U-BOLT, 0.25-20 ALLOY			0			
	50821 WASHER, FLAT			0			
	50815 WASHER, LOCK			0			
	50809 NUT, 000.250			0			
	51239 FITTING, SS UNION			0			
	52120 CLAMP, WORM GEAR			0			
	51002 TAPE, INSULATION			0			
	50817 WASHER, LOCK			0			

Costs for WO #02-60456-0 AND ALL ASSOCIATED SUBS

MO.NO.....	Description.....	Part No	Part Noun Qual.....	Part Qty Issued	Tot Material Act	Act Tot Labor Cost	Actual Tot Cost
02-60456-18	FABRICATE DOOR FRAME FOR NEW OVERFIRE AIR DOORS. (PHIL HATLES)	50108	ANTI-SEIZE, LO TEMP	0			
		31334	FITTING, SS TUBE ADAPTER	0			
		51109	FITTING, SS BULKHEAD	0			
		33021	STEEL, CHANNEL	22	432.04	1,055.26	1,487.30
		66252	STEEL, CHANNEL	24			
02-60456-19	UNIT 1 "OVER-FIRE CONTRACTOR COST TRACKER" (FOR KEN NIELSON) FOR MATERIALS USED	29189	STEEL, PLATE	80			
		54713	STEEL, TUBING	146	333.13	343.60	676.73
		19911	UNISTRUT, CHANNEL	0			
		43101	UNISTRUT, CHANNEL	0			
		18284	UNISTRUT, CHANNEL	0			
02-60456-20	UNIT 1 "OVER-FIRE CONTRACTOR COST TRACKER" (FOR PHIL HATLES) FOR WINDBOX DUCT INSTALLATION	25438	PIPE, SEAMLESS	0			
		7737	CAP, 01.25 THREADED	0			
		25440	PIPE, SEAMLESS	0			
		7738	CAP, 01.50 THREADED	0			
		54346	NDT, CLEANER	0			
02-60456-21	INSTALL TEMP. POWER IN THE UNIT TWO BOILER AREA AS IT WAS IN THE UNIT ONE BOILER FOR THE OVER FIRE AIR PROJECT.	D	OVERFIRE AIR DUCT	108	145.80	0.00	145.80
			MECHANICAL/STRUCTURAL TIME AND				
			MATERIAL WORK BY TEI, TO MAKE				
			MODIFICATIONS BEYOND ORIGINAL				
			SCOPE OF CONTRACT				
02-60456-22	RETROFIT BOILER VENT FAN 44 AND DUCT WORK IMPACTED BY OVERFIRE AIR MODIFICATION		**CONTRACT ADMINISTRATOR, PHIL HAILES**				
		50901	PIN, COTTER	0			
		3156	WELD MATERIAL, ELECTRODE	0			
		5273	WELD MATERIAL, ELECTRODE	0			
		12159	TEE, 02.00 SOCKETWELD	0	0.00	0.00	0.00
02-60456-22	RETROFIT BOILER VENT FAN 44 AND DUCT WORK IMPACTED BY OVERFIRE AIR MODIFICATION	29494	TRANSMITTER, TEMPERATURE	7	73.05	0.00	73.05
		62221	SWITCH, DIFF.PRESSURE	0			
		D	TUBE, SENSING, AIR FLOW, JOHNSON CONTROLS P/N FTG18A600R	0			
		D	FLANGE, SINGLE, JOHNSON CONTROLS P/N T-800-1603	0			

Costs for WO #02-60456-0 AND ALL ASSOCIATED SUBS

MO.NO.....	Description.....	Part No	Part Noun Qual.....	Part Qty Issued	Tot Material Act	Act Tot Labor Cost	Actual Tot Cost
		D	ASSEMBLY, TEST PROBE, JOHNSON CONTROLS P/N JC 5361	0			
		30552	COMPOUND, SEALANT	0			
		54203	BANDING, MATERIAL	0			
02-60456-23	UNIT 1 "OVER-FIRE CONTRACTOR COST TRACKER" (FOR PHIL HAILES) FOR HVAC DUCT RELOCATION	50638	ROD, ALLTHREAD	87	206.88	564.38	771.26
		53506	STEEL, SHEET	0			
		30300	PAINT, SPRAY	0			
02-60456-24	RETURN PRINTED OUTPUT BOARD TO FOXBORO FOR REPAIR/REPLACEMENT.	D	REPAIR/REPLACE AND RETURN: BOARD, PRINTED OUTPUT FOXBORO P/N 3A2-D2I IPSC STOCK #2627	0	0.00	0.00	0.00
					=====	=====	=====
					1,623,388.77	88,178.99	1,711,567.76

25 records listed.